

SECTION 270544 - SLEEVES AND SLEEVE SEALS FOR COMMUNICATIONS PATHWAYS AND CABLING

Latest Update 09-09-2021 See underlined text for Edits.

(Engineer shall edit specifications and blue text in header to meet project requirements. This includes but is not limited to updating Equipment and/or Material Model Numbers indicated in the specifications and adding any additional specifications that may be required by the project. Also turn off all “Underlines”.)

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this section and all other sections of Division 27.

1.2 SUMMARY

- A. Section Includes:

- 1. Sleeves for pathway and cable penetration of non-fire-rated construction walls and floors.
- 2. Sleeve-seal systems.
- 3. Sleeve-seal fittings.
- 4. Grout.
- 5. Silicone sealants.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product specified in this section.

- B. LEED Submittals:

- 1. Product Data for Credit EQ 4.1: For sealants, documentation including printed statement of VOC content

1.4 WARRANTY/GUARANTEE

- A. See Division 26 Specification Section “Basic Electrical Requirements’ for warranty and guarantee requirements.

PART 2 - PRODUCTS

2.1 SLEEVES

A. Wall and Floor Sleeves:

1. Steel Pipe Sleeves: ASTM A 53/A 53M, Type E, Grade B, Schedule 40, zinc coated, plain ends.

B. Non-Fire-Rated Soundproof Partition Penetrations: Where new and existing cables pass through interior partitions with sound proofing provide pipe sleeves. Seal the annular spaces between construction openings, the sleeves and cables with soundproof insulation material equal to the width of the opening. The soundproof insulation shall match the insulation in the partition.

C. Sleeves for Rectangular Openings:

1. Material: Galvanized-steel sheet.
2. Minimum Metal Thickness:
 - a. For sleeve cross-section rectangle perimeter less than fifty (50) inches and with no side larger than sixteen (16) inches, thickness shall be 0.052 inch.
 - b. For sleeve cross-section rectangle perimeter fifty (50) inches or more and one or more sides larger than sixteen (16) inches, thickness shall be 0.138 inch.

2.2 FIRE STOPS & SMOKE SEALS FOR WALL & FLOOR SLEEVE APPLICATIONS

A. General: Provide fire stops, and smoke sealant materials for all electrical communication services penetrating through rated assemblies. See Architectural Specification Division 07, Section “Penetration Firestopping” for sealant material requirements. Services include:

1. Electrical communication penetrations include conduits and cables.

B. New Construction: All new penetrations shall be provided with a pipe sleeve and sealant materials.

C. Existing Construction: All new service penetrations through existing rated assemblies shall be provided with a pipe sleeve and sealant materials. All existing unsealed penetrations for services passing through existing rated assemblies within the project area shall be provided with sealant materials.

- D. Project Area: The project area shall include the finished spaces and related sections of the utility shafts within the project area footprint.
- E. Wall Pipe Sleeve Applications: Pipe sleeves shall be required for all new conduit penetrations through rated wall assemblies and non-rated CMU walls. Where pipe sleeves are installed in non-rated CMU walls fire rated sealant materials are not required. Provide acoustical caulking to seal the annular spaces between the sleeve and the bare pipe or pipe insulation on each end with one half (1/2) inch caulking all around the annular space.
- F. Floor Pipe Sleeves Applications: Pipe sleeves are required for all new conduit risers passing through floor slabs.

2.3 SLEEVE-SEAL SYSTEMS

- A. Description: Modular sealing device, designed for field assembly, to fill annular space between sleeve and pathway or cable.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one (1) of the following:
 - a. Advance Products & Systems, Inc.
 - b. CALPICO, Inc.
 - c. Metraflex Company (The).
 - d. Pipeline Seal and Insulator, Inc.
 - e. Proco Products, Inc.
 - 2. Sealing Elements: EPDM rubber interlocking links shaped to fit surface of pipe. Include type and number required for pipe material and size of pipe.
 - 3. Pressure Plates: Stainless steel.
 - 4. Connecting Bolts and Nuts: Stainless steel of length required to secure pressure plates to sealing elements.

2.4 SLEEVE-SEAL FITTINGS

- A. Description: Manufactured plastic, sleeve-type, waterstop assembly made for embedding in concrete slab or wall. Unit shall have plastic or rubber waterstop collar with center opening to match piping OD.
 - a. Manufacturers: Subject to compliance with requirements, provide products by the following Pre-sealed Systems.
 - b. <Insert manufacturer's name>.

2.5 GROUT

- A. Description: Nonshrink; recommended for interior and exterior sealing openings in non-fire-rated walls or floors.
- B. Standard: ASTM C 1107/C 1107M, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
- C. Design Mix: 5,000-psi, twenty eight (28) day compressive strength.
- D. Packaging: Premixed and factory packaged.

2.6 SILICONE SEALANTS

- A. Silicone Sealants: Single-component, silicone-based, neutral-curing elastomeric sealants of grade indicated below.
 - 1. Grade: Pourable (self-leveling) formulation for openings in floors and other horizontal surfaces that are not fire rated.
 - 2. Sealant shall have VOC content of 250 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- B. Silicone Foams: Multicomponent, silicone-based liquid elastomers that, when mixed, expand and cure in place to produce a flexible, nonshrinking foam.

PART 3 - EXECUTION

3.1 SLEEVE INSTALLATION FOR NON-FIRE-RATED ELECTRICAL PENETRATIONS

- A. Comply with NECA 1.
- B. Comply with NEMA VE 2 for cable tray and cable penetrations.
- C. Sleeves for Conduits Penetrating Above-Grade Non-Fire-Rated Concrete and Masonry-Unit Floors and Walls:
 - 1. Interior Penetrations of Non-Fire-Rated Walls and Floors:
 - a. Seal annular space between sleeve and pathway or cable, using joint sealant appropriate for size, depth, and location of joint. Comply with requirements in Division 07 Section "Joint Sealants."

3.3 SLEEVE-SEAL-FITTING INSTALLATION

- A. Install sleeve-seal fittings in new walls and slabs as they are constructed.
- B. Assemble fitting components of length to be flush with both surfaces of concrete slabs and walls. Position waterstop flange to be centered in concrete slab or wall.
- C. Secure nailing flanges to concrete forms.
- D. Using grout, seal the space around outside of sleeve-seal fittings.

END OF SECTION 270544